

變電所	主變	饋線	拱位	核發容量 (kW)	保留容量 (kW)	總核發容量 (kW)	饋線可併網 容量 (kW)	饋線最低 負載 (kW)	主變最低負載 (kW)	主變可併網容量 (kW)
馬公變電所	一號主變	RA09	F12	1186	0	4462	 3933	1448	5996	 21980
		RA14	F18	0	0		 5000	1116		
		RA16	F17	815	0		 0	863		
		RA17	F16	0	0		 0	604		
		RA19	F13	89	0		 0	916		
		RA20	F11	2372	0		 0	1049		
	二號主變	RA02	F27	3136	0	10136	 2178	857	6965	 17843
		RA05	F25	110	0		 4901	1454		
		RA07	F24	36	0		 4968	618		
		RA11	F22	4450	0		 995	1023		
		RA21	F29	2016	0		 3186	1700		
		RA25	F28	0	0		 0	378		
	三號主變	RA27	F21	388	0	18042	 0	936	6919	 10681
		RA03	F32	325	0		 4708	876		
		RA04	F38	3055	0		 2251	657		
		RA06	F31	0	0		 0	664		
		RA08	F33	2132	500		 0	1521		
		RA13	F35	3675	0		 1692	1819		
尖山變電所	一號主變	RA15	F37	4006	0	8320	 0	803	6248	 18760
		RA22	F34	4000	350		 0	578		
	四號主變	RA01	F42	21	0		 4981	644		
		RA12	F47	3700	0		 1670	950		
		RA18	F46	641.46	0		 0	1720		
		RA26	F43	2851	0		 2434	1242		
		RA28	F41	550	0		 4505	1222		
		RA29	F45	556	0		 4499	471		
	二號主變	RH03	L13	1500	0	26255	 3650	607	4135	 0
		RH05	L14	3613	0		 1749	1756		
		RH07	L15	3293	0		 2036	1116		
		RH13	L12	1832	800		 2631	656		
		RHA1	L11	5400	0		 5140			
		RHC1	L17	9817	0		 1165			
	三號主變	RH02	L22	2327	181	26583	 2743	1213	4663	 0
		RH06	L24	2406	1085		 1858	1259		
		RH11	L21	424	1200		 3539	795		
		RH14	L23	4773	370		 372	1396		
		RHA0	L25	4000	0		 6400			
		RHC2	L27	9817	0		 1165			
			L28							
	四號主變	RH01	L33	997	0	20928	 4102	830	4959	 0
		RH04	L34	1516	140		 3510	1003		
		RH08	L31	1507	0		 3644	656		
		RH10	L32	1506	0		 3645	2470		
		RHC0	L37	5445	0		 5100			
		RHC3	L39	9817	0		 1165			

 < 1 MW

 1~3 MW

 > 3 MW

 < 5 MW

 5~10 MW

 > 10 MW