

變電所	主變	饋線	拱位	核發容量 (kW)	保留容量 (kW)	總核發容量 (kW)	饋線可併網 容量 (kW)	饋線最低 負載 (kW)	主變最低負載 (kW)	主變可併網容量 (kW)	
馬公變電所	一號主變	RA09	F12	1196	0	4473	 3923	1448	5996	 21971	
		RA14	F18	0	0		 5000	1116			
		RA16	F17	815	0		 0	863			
		RA17	F16	0	0		 0	604			
		RA19	F13	89	0		 0	916			
		RA20	F11	2372	0		 0	1049			
	二號主變	RA02	F27	3136	0	10400	 2178	857	6965	 17606	
		RA05	F25	110	0		 4901	1454			
		RA07	F24	46	0		 4958	618			
		RA11	F22	4464	0		 982	1023			
		RA21	F29	2016	240		 2970	1700			
		RA25	F28	0	0		 0	378			
		RA27	F21	388	0		 0	936			
	三號主變	RA03	F32	325	0	16062	 4708	876	6919	 12463	
		RA04	F38	1075	0		 4033	657			
		RA06	F31	0	0		 0	664			
		RA08	F33	2132	500		 0	1521			
		RA13	F35	3675	0		 1692	1819			
		RA15	F37	4006	0		 0	803			
	四號主變	RA22	F34	4000	350	8349	 0	578	6248	 18734	
		RA01	F42	21	0		 4981	644			
		RA12	F47	3710	0		 1661	950			
		RA18	F46	641.46	0		 0	1720			
		RA26	F43	2869	0		 2418	1242			
RA28		F41	550	0	 4505		1222				
尖山變電所	一號主變	RA29	F45	556	0	16615	 4499	471	4135	 0	
		RH03	L13	1500	0		 3650	607			
		RH05	L14	3638	107		 1630	1756			
		RH07	L15	3289	0		 2040	1116			
		RH13	L12	1882	800		 2587	656			
		RHA1	L11	5400	0		 5140				
	二號主變					16642			4663	 0	
		RH02	L22	2463	181		 2621	1213			
		RH06	L24	2156	1085		 2083	1259			
		RH11	L21	415	1200		 3547	795			
		RH14	L23	4773	370		 372	1396			
		RHA0	L25	4000	0		 6400				
	三號主變					7158			4959	 0	
		RH01	L33	997	0		 4102	830			
		RH04	L34	1516	140		 3510	1003			
		RH08	L31	1519	0		 3633	656			
		RH10	L32	1506	1480		 2313	2470			
	尖風變電所	一號主變	RKE0	220	15654	0	35288.12	 5912			 8232
			RKE1	230	19634	0		 2329			