

變電所	主變	饋線	拱位	核發容量 (kW)	保留容量 (kW)	總核發容量 (kW)	饋線可併網 容量 (kW)	饋線最低 負載 (kW)	主變最低負載 (kW)	主變可併網容量 (kW)
馬公變電所	一號主變	RA09	F12	1197	0	1197	 3923	1448	2071	 20994
		RA14	F18	0	0		 5000	624		
		RA16	F17	0	0		 0	0		
		RA17	F16	0	0		 0	0		
		RA19	F13	0	0		 0	0		
		RA20	F11	0	0		 0	0		
	二號主變	RA02	F27	3097	0	10043	 2213	857	5651	 16612
		RA05	F25	110	0		 4901	1454		
		RA07	F24	46	0		 4958	618		
		RA11	F22	4534	0		 920	1023		
		RA21	F29	2016	240		 2970	1700		
		RA25	F28	0	0		 0	0		
		RA27	F21	0	0		 0	0		
	三號主變	RA03	F32	325	0	8141	 4708	876	4874	 17547
		RA04	F38	1075	0		 4033	657		
		RA06	F31	0	0		 0	0		
		RA08	F33	2132	500		 0	1521		
		RA13	F35	3760	0		 1616	1819		
		RA15	F37	0	0		 0	0		
	四號主變	RA22	F34	0	350	7247	 0	0	4528	 18006
		RA01	F42	21	0		 4981	644		
		RA12	F47	3730	0		 1643	950		
		RA18	F46	0	0		 0	0		
		RA26	F43	2372	0		 2865	1242		
		RA28	F41	567	0		 4490	1222		
尖山變電所	一號主變	RA29	F45	556	0	16630	 4499	471	6758	 0
		RH03	L13	1500	0		 3650	607		
		RH05	L14	4452	107		 896	2619		
		RH07	L15	3289	0		 2040	1720		
		RH13	L12	1882	0		 3307	1812		
		RHA1	L11	5400	0		 5140			
	二號主變					17431			6894	 0
		RH02	L22	4855	0		 631	2262		
		RH06	L24	2200	0		 3020	2062		
		RH11	L21	434	0		 4609	1174		
		RH14	L23	4773	370		 372	1396		
		RHA0	L25	4800	0		 5680			
	三號主變					7617			9109	 0
		RH01	L33	1029	0		 4074	830		
		RH04	L34	1554	100		 3511	1580		
		RH08	L31	1548	0		 3606	656		
		RH10	L32	1904	1480		 1954	3406		
尖風變電所	一號主變	RKE0	220	15485	0	35119.735	 6063			 8383
		RKE1	230	19634	0		 2329			

 < 1 MW
 1~3 MW
 > 3 MW

 < 5 MW
 5~10 MW
 > 10 MW